

Facility Summary in Treasure County in the City of Hysham

Location: FRIENDLY CORNER
718 Elliot Ave
Hysham, MT 59038 Treasure

System Facility ID:52-06316

Facility Code: 29186
Last Inspected On: 07/02/2021
Operating Permit Renewal Date: 09/29/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Cross Petroleum Services Billings 4062525519

Operator Contact: Gregory Cross;R J Serpe;Timothy Fife

Owner/Operator: Cross Petroleum Services Billings

Greg Cross, UST Class A Operator
R J Serpe, UST Class A Operator
R J Serpe, UST Class B Global Operator
Shelli Thrower, UST Class B Operator
Timothy Fife, UST Class A Operator

Tank Code	01	Tank Age	43	Tank Installed Date	08/01/1979	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1405	Spill Test Date	07/02/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/10/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/09/2022	Line Tightness Test Date	03/24/2012	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/02/2021			ATG Type	Franklin Fueling Systems/TS-LS500 Series;Incon/TS-550 EVO				
Tank Code	02	Tank Age	43	Tank Installed Date	08/01/1979	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1406	Spill Test Date	07/02/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/10/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	10000	ATG Test Date	08/09/2022	Line Tightness Test Date	04/01/2012	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/02/2021			ATG Type	Franklin Fueling Systems/TS-LS500 Series;Incon/TS-550 EVO				
Tank Code	03	Tank Age	43	Tank Installed Date	08/01/1979	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1407	Spill Test Date	07/02/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/10/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	3000	ATG Test Date	08/09/2022	Line Tightness Test Date	04/05/2012	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/02/2021			ATG Type	Franklin Fueling Systems/TS-LS500 Series;Incon/TS-550 EVO				

Facility Summary in Treasure County in the City of Hysham

Location: VALLEY FARMERS SUPPLY HYSHAM
121 Elliot Ave
Hysham, MT 59038 Treasure

System Facility ID:52-01905

Facility Code: 29169
Last Inspected On: 11/16/2020
Operating Permit Renewal Date: 02/27/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Valley Farmers Supply4069673100

Operator Contact: Scott Black4069673100

Owner/Operator: Valley Farmers Supply

- Earl Mitchell, UST Class B Operator
- Scott Black, UST Class A Operator
- Scott Black, UST Class B Global Operator
- Shawn Hedges, UST Class B Operator
- Sheryl Warren, UST Class B Operator

Tank Code	03	Tank Age	32	Tank Installed Date	07/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3144	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/16/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/31/2021			ATG Type	Veeder Root/TLS-300				
Tank Code	04	Tank Age	32	Tank Installed Date	07/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3145	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/16/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/31/2021			ATG Type	Veeder Root/TLS-300				